




RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

| TEST REPORT | | | | | |
|---|--|-----------|--|---|-------------------------------|
| Address of the sampling location : THE DEEN ACADEMY No. 64/1, & 65/2, ECC Road Whitefeild, Bengaluru-560066 | | | | Report date: 18/04/2026 | |
| | | | | Report Number: 006 | |
| | | | | Reference: TRF | |
| | | | | Sample code: 006 | |
| | | | | Date of Sample collection: 15/04/2026 | |
| | | | | Analysis start date: 15/04/2026 | |
| | | | | Analysis completion date: 17/04/2026 | |
| Sample quantity: 1 Liter | | | | | |
| Sample Particulars: R O water | | | | | |
| Sl. No | Test | Results | Acceptable Limit IS 10500 : 2012 RA:2018 | Permissible Limit IS 10500 : 2012 RA:2018 | Protocol |
| Description: Colourless liquid | | | | | |
| 1 | pH Value @25°C Temp | 7.1 | 6.5 – 8.5 | No relaxation | IS 3025 (Part-11) : 2022 |
| 2 | Specific Conductance, µS/cm @25°C Temp | 100 | - | - | IS 3025 (Part-14) : 2013 |
| 3 | Odour | Agreeable | Agreeable | Agreeable | IS 3025 (Part-5 & 6):2018 |
| 4 | Colour, Hazen Units | < 1.0 | 5 | 15 | IS 3025 (Part-4) :2021 |
| 5 | Turbidity, NTU | 0.0 | 1 | 5 | IS 3025 (Part-10) : 2023 |
| 6 | Total Dissolved Solids, mg/l @180°C | 60 | 500 | 2000 | IS 3025 (Part-16) : 2023 |
| 7 | Alkalinity as CaCO ₃ , mg/l | 20.5 | 200 | 600 | IS 3025 (Part-23) : 2023 |
| 8 | Total Hardness as CaCO ₃ , mg/l | 15.9 | 200 | 600 | IS 3025 (Part-21) : 2009 |
| 9 | Calcium as Ca, mg/l | 3.2 | 75 | 200 | IS 3025 (Part-40) : 1991 |
| 10 | Magnesium as Mg, mg/l | 2.0 | 30 | 100 | IS 3025 (Part-46) : 2023 |
| 11 | Chloride as Cl, mg/l | 9.5 | 250 | 1000 | IS 3025 (Part-32) : 1988 |
| 12 | Sulphate as SO ₄ , mg/l | 6.3 | 200 | 400 | IS 3025 (Part-24) : 2022 |
| 13 | Fluoride as F, mg/l | 0.0 | 1 | 1.5 | APHA 24 th Edition |
| 14 | Nitrate as NO ₃ , mg/l | 4.5 | 45 | No relaxation | APHA 24 th Edition |
| 15 | Iron as Fe, mg/l | 0.0 | 1 | No relaxation | IS 3025 (Part-53) : 2003 |
| Remark: The above given sample conforms to the Acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only. | | | | | |
| Analysed by: <i>Megha K. S</i> Senior Analyst/Junior Analyst | | | Authorized Signatory: <i>Pavithra B.S</i> Technical Manager: Pavithra B.S | | |



RDWSD/WQMSF/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSF/DR-01

---END---

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 006

Date :18-04-2026


It is certified that an inspection team headed by Pavithra B S Sr. Analyst RDWSD District Laboratory Bangalore (Name of Officers with designation) from RDWSD District Laboratory Bangalore (Name of Department/Office) inspected THE DEEN ACADEMY School (Name & Address of the School) Bangalore - 560066 on 15-04-2026 and found that The Deen Academy School No.64/1 & 65/2, ECC Road whitefield, Bangalore-560066 (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 17-04-2027

Signature with Seal:

Name

Designation


 District Laboratory
 Tasting Drinking Water
 Tasting District Laboratory
Pavithra B S.
 Bangalore
Sr. Analyst

To

THE DEEN ACADEMY
No.64/1 & 65/2, ECC Road whitefield
Bangalore-560066

